



HALOTRON LABEL WARNINGS (See NFPA 13 5.3.2.6*)

All Halon 1211 extinguishers, for toxicity reasons, had a minimum volume size noted on the “Warning” portion of their nameplates (labels). Halotron I extinguishers have similar warnings on their nameplates. The table below lists the minimum volume size recommended for Halotron I, and for comparison, minimum volume recommended for an equivalent size Halon 1211 extinguisher is also noted. Halotron I required only a slightly larger volume, pound for pound, than Halon 1211.

Model	Size	Minimum Volume (actual size) Halotron I	Minimum Volume (if same size) Halon 1211
A384T	1.4 lb.	196 cu. ft.	175 cu. ft.
A385TS	2 ½ lb.	350 cu. ft.	312 cu. ft.
A386T	5 lb.	700 cu. ft.	625 cu. ft.
394TS	5 ½ lb.	770 cu. ft.	
387	11 lb.	1540 cu. ft.	1372 cu. ft.
388	15 ½ lb.	2170 cu. ft.	1933 cu. ft.

As stated in the Halotron I Owner’s Manual, these extinguishers are NOT intended for residential use.